

Statutory guidance: SR2009 No 4: combustion of biogas in engines at a sewage treatment works

Updated: We updated SR2009 No 4: combustion of biogas in engines at a sewage treatment works.

Standard rules and generic risk assessment for compression and spark ignition engines with an aggregated total rated thermal input of less than 5 megawatts to burn biogas produced from the digestion of sewage sludge at a sewage treatment works.

You can apply online for most standard rules environmental permits.

[Apply for a standard rules environmental permit.](#)