

## Statutory guidance: SR2018 No 8: mobile plant Specified Generator, Tranche B low risk, base load operation <1 – 2 MWth

When referred to in an environmental permit these rules will authorise one Tranche B Specified Generator which is a diesel fired engine between <1-2MWth. It may be deployed to a given location in rural and urban areas where background NO<sub>2</sub> has sufficient headroom.

Applies to Specified Generator burning ultra-low sulphur diesel (10 ppm sulphur) only.