

Statutory guidance: SR2018 No 9: Specified Generator, Tranche B low risk, base load operation between 0 – 0.9 MWth

When referred to in an environmental permit these rules will allow the operator to operate one or more unabated Tranche B Specified Generators which are natural gas fired engines or boilers which are CHPs. Individual unit capacity less than 0.9MWth and the total less than 0.9 MWth at the specified location.

Applies to Specified Generator burning only natural gas.